



320316



cc: records  
Region 6

Fred H. Steinkuehler  
Director-Engineering and  
Environmental Quality Control

Granite City Division  
National Steel Corporation  
20th & State Streets  
Granite City, Illinois 62040  
(618) 451-3281

June 14, 1991

CERTIFIED MAIL NO. P 430 864 031  
RETURN RECEIPT REQUESTED

Illinois Environmental Protection Agency  
Division of Water Pollution Control  
Compliance Management Unit  
2200 Churchill Road  
Springfield, Illinois 62706

Subject: NPDES Permit IL0000329

Gentlemen:

This letter is submitted in accordance with Section A.2 of Part II of the above subject permit and the Thomas G. McSwiggin memorandum of October 24, 1977.

The following results have been reported to me for the fecal coliform parameter for our discharge monitoring samples:

June 6, 1991

540 Colonies/100 ml

This level is above the daily maximum allowed in the subject permit.

There were no known upsets in the Granite City Division production or wastewater treatment facilities which would have caused such a level as reported above. Control of this parameter has consistently been demonstrated in the waste stabilization basins.

Should additional information be required, please contact my office or that of Carl Cannon (618) 451-3013.

Respectfully,

Fred Steinkuehler  
Director-Engineering & EQC

cc: USEPA, Region V  
230 South Dearborn  
Chicago, Illinois 60604  
CERTIFIED MAIL NO. P 430 864 032

TGM/NPDES

RECEIVED  
Compliance Assurance Section  
JUN 20 1991  
Environmental Protection Agency  
STATE OF ILLINOIS